WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46704
Permit No.
Basin 089

NOTICE OF INTENT NO. 24224

1. OWNER C J Hadley
MAILING ADDRESS 43 Bellview
Carson City NV 89706

ADDRESS AT WELL LOCATION 43 Bellview
Carson City NV 89706

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 16 N R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 55-169-02 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Overburden		0	6	6
Rust Sands		6	12	6
Sandy Gravels		12	34	22
Brown Clay		34	87	53
Brown Clay and Coarse Sands		87	110	23
Hard DG Granite w/Small Fractures		110	180	70

'94 OCT 26 P2:03
STATE ENGINEER'S OFFICE

Date started 10-19, 1994
Date completed 10-25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10¼ Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.088	.188	0	180

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 (Contractor)
Carson City NV 8701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L. Hack (By driller performing actual drilling on site or contractor)
Date 10-5-94

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627