WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46710
Permit No.
Basin 049

NOTICE OF INTENT NO. R2896

1. OWNER DEW INC
MAILING ADDRESS P.O. Box 3111
Elko NV 89801

ADDRESS AT WELL LOCATION 12 North of Elko on MT City Highway Lot 4 on Heaney Bo Road

2. LOCATION NE ¼ NE ¼ Sec. 3 T. 35 N/S R. 55 E Elko County

PERMIT NO. ____ Issued by Water Resources | 05-520-15-0 Parcel No. | ADOBE Ranhcos Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	3	3
Sandstone		3	18	15
Clay		18	149	131
White Sandstone		149	164	15
Lose white sandstone	X	164	170	6

'94 DEC 27 P1:18
STATE ENGINEER'S OFFICE

Date started 12-6, 1994
Date completed 12-12, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45+	NV	3.5

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	170 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	170

Perforations:
Type perforation Slots
Size perforation 3/16 x 3"
From 150 feet to 170 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From ~~170~~ 116 feet to 170 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling co (Contractor)
Address PO Box 525 (Contractor)
Elko NV 89801

Nevada contractor's license number issued by the State Contractor's Board 31904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shorel C Fertig Jr
By driller performing actual drilling on site or contractor

Date 12-12-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627