

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26576

1. OWNER JOHN TIMMONS ADDRESS AT WELL LOCATION 224 FOOTHILL MEADOWS
 MAILING ADDRESS P.O. Box 1848 GENOA, NV
MINDEN, NV 89423

2. LOCATION SW 1/4 NW 1/4 Sec 10 T 13 N R 19 E DOUGLAS County
 PERMIT NO. 17-084-42 GENOA Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	9	9
SAND + GRAVEL		9	35	26
CLAY		35	41	6
GRAVEL	✓	41	75	34
CLAY		75	81	6
DG		81	97	16
SANDY CLAY		97	100	3
SAND + GRAVEL		100	107	7
SANDY CLAY		107	111	4
COBBLES		111	116	5
DG		116	132	16
DG + SANDY CLAY	✓	132	180	48

94 NEW - 9 AT 116
 STATIONED

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>50</u>	Feet
<u>9 7/8</u>	<u>50</u>	<u>180</u>	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>11</u>	<u>180</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32

From	feet to	feet
<u>60</u>	<u>80</u>	feet
<u>160</u>	<u>180</u>	feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to _____ feet

9. WATER LEVEL
 Static water level 38 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality GOOD

Date started 10-24, 1994
 Date completed 10-27, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>AIR</u>	<u>25+</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLEN, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10-27-94