

46714

Log No. _____
Permit No. _____
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26569

1. OWNER M.R. + MRS. HENDERSON ADDRESS AT WELL LOCATION 2366 CALLE DEL SOL
MAILING ADDRESS CHIMACUM, WA. GARDNERVILLE

2. LOCATION NE 1/4 SE 1/4 Sec 32 T. 13 N. R. 21 E. DOUGLAS County
PERMIT NO. 23-430-11 Parcel No. _____ Subdivision Name FISH SPRINGS

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	35	35
SANDY CLAY w/ GRAVEL		35	53	18
CLAY		53	61	8
CEMENTED GRAVEL		61	74	13
SANDY CLAY w/ GRAVEL		74	97	23
CEMENTED GRAVEL		97	121	24
SAND + GRAVEL	✓	121	129	8
CEMENTED GRAVEL	✓	129	161	32
SANDY CLAY w/ GRAVEL		161	170	9
CEMENTED GRAVEL	✓	170	198	28
SANDY CLAY w/ GRAVEL		198	200	2

'94 NOV -9 AM 11:16
 STATE ENGINEER

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

From (Inches)	To (Feet)
<u>10 5/8</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>9 7/8</u> Inches	<u>50</u> Feet <u>200</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>200</u>

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 180 feet to 200 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
Address 7780 CURRY RD. Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Pat J. Moore
By driller performing actual drilling on site of contractor
Date 10-20-94

Date started 10-18, 1994
Date completed 10-20, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>2</u>