

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27519

1. OWNER JOHN DECARLO ADDRESS AT WELL LOCATION 1446 CALLE PEQUENO
MAILING ADDRESS GARDNERVILLE, NV FISH SPRINGS, NV

2. LOCATION SE 1/4 SW 1/4 Sec 32 T 13 (N) S R 21 E DOUGLAS County
PERMIT NO. _____ Parcel No. 23-190-06 Subdivision Name FISH SPRINGS

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MOD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/ GRAVEL		0	9	9
CEMENTED GRAVEL		9	16	7
SANDY CLAY w/ GRAVEL		16	39	23
SAND + GRAVEL		39	48	9
SANDY CLAY w/ GRAVEL		48	74	26
SAND + GRAVEL		74	81	7
SANDY CLAY w/ GRAVEL		81	102	21
SAND + GRAVEL	✓	102	111	9
SANDY CLAY w/ GRAVEL		111	115	4
SAND + GRAVEL	✓	115	127	12
SANDY CLAY w/ GRAVEL		127	134	7
CLAY		134	140	6

94 NOV -9 AM 11:16
STATE OF NEVADA

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>12 5/8</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>9 7/8</u> Inches	<u>50</u> Feet <u>140</u> Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 120 feet to 140 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDO EXPLORATION INC Contractor
Address 7780 CURRY RD. Contractor
FALCON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Pat J. McCoy
By driller performing actual drilling on site or contractor
Date 10-17-94

Date started 10-15, 1994
Date completed 10-17, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>