

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26570

1. OWNER BARBARA BACK ADDRESS AT WELL LOCATION GENOA ST
 MAILING ADDRESS TOPAZ, NV TOPAZ, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 29 T. 10 N. R. 22 E DOUGLAS County
 PERMIT NO. 39-070-08 TOPAZ LAKE Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Aluvial Fill w/ clay</u>		<u>0</u>	<u>108</u>	<u>108</u>
<u>Basalt w/ Fractures</u>		<u>108</u>	<u>127</u>	<u>19</u>
<u>Dyserite some Basalt Fract</u>	<input checked="" type="checkbox"/>	<u>127</u>	<u>176</u>	<u>49</u>
<u>Dyserite Broken</u>	<input checked="" type="checkbox"/>	<u>176</u>	<u>195</u>	<u>19</u>
<u>Dyserite some Fractures</u>		<u>195</u>	<u>210</u>	<u>15</u>

'94 NOV -9 11:16
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>100</u> Feet
<u>9 1/2</u> Inches	<u>100</u> Feet	<u>210</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>210</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 190 feet to 210 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100 feet to 210 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 9-28, 1994
 Date completed 10-6, 1994

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25 +</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed Jerald W. Shinn
 By driller performing actual drilling on site or contractor
 Date 10-6-94