WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46725
Permit No.
Basin 102

NOTICE OF INTENT NO. 24684

1. OWNER Sherry D. Bohland
MAILING ADDRESS P.O. Box 77 Silver Springs, NV 89429
ADDRESS AT WELL LOCATION 1665 6th St. Silver Springs, NV 89429

2. LOCATION NE ¼ SW ¼ Sec. 18 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. — Issued by Water Resources | 18-282-06 Parcel No. | Stockman Sub #5 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fine sand		0	8	8
red volcanic rock		8	55	47
black + red volcanic rock	X	55	100	45
facture				

Started well a month ago + rig broke. Hard to find gear for drilling table.
gear is off of 1½ ton "52" Ford

Date started 9-16, 1994
Date completed 10-23, 1994

RECEIVED STATE ENGINEERS OFF NOV -8 A10:41 '94

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	1	2

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 100 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	100

Perforations:
Type perforation Mill
Size perforation 1/8 x 3
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACE Drilling + Dev. Contractor
Address P.O. Box 668 Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed [signature] By driller performing actual drilling on site or contractor
Date 10-24-1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627