X WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46726
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 26619

1. OWNER John Binkley
MAILING ADDRESS 7100 Citrus Street Silver Springs, NV 89429
ADDRESS AT WELL LOCATION 7100 Citrus Street Silver Springs, NV 89429

2. LOCATION NE ¼ NW ¼ Sec. 13 T. 17 N/S R. 24 E. Lyon County
PERMIT NO. ____ Issued by Water Resources | 17-234-03 Parcel No. | Butte No. 2 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil And Rock		0	3	3
Tan Clay		3	37	35
Tan Clay With Some Rock		37	59	22
Brown Clay		59	126	67
Boulders		126	146	20
GRAY Clay		146	200	54
Red Rock with Cracks	✓	200	240	40

'94 NOV -7 P3 42
RECEIVED
STATE ENGINEERS OFF

Date started 10-12, 1994
Date completed 10-14, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 2 Hours And produced about 20 Gallons A min			

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 237 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
7 7/8 Inches	60 Feet	240 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	237

Perforations:
Type perforation Torch Cut
Size perforation 1/4 x 6 Long x 5 Row
From 227 feet to 237 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 PER TELCON W/ LEACH
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 237 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address Po Box 599
Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1877
Signed [signature]
By driller performing actual drilling on site or contractor
Date 10-28-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627