

OFFICE USE ONLY
 Log No. 410-227
 Permit No. 385
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27306

1. OWNER WILLIAM J. KOHR ADDRESS AT WELL LOCATION parcel C
 MAILING ADDRESS 595 Valle Verde Drive Same
Sparks, Nevada 89436
 2. LOCATION SE SE4 1/4 Sec. 1810 21N N/S R. 21 E Washoe County
 PERMIT NO. 076-690-07 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown clay some smaller boulders		1	8	7
White clay		8	16	8
Brown clay		16	22	8
Red clay		22	31	9
White clay		31	43	12
Brown clay		43	91	48
White clay		91	130	39
Brown sandy clay		130	240	110
Gray clay		240	270	30
Brown sandy clay		270	340	70
Brown volcanic rock		340	360	20
Black volcanic rock		360	438	78
Brown volcanic rock		438	449	11
Fracture	X	449	456	7
Brown volcanic rock		456	492	36
Fracture	X	492	495	3
Brown volcanic rock		495	500	5

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 5 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 5/8 Inches 0 Feet 500 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	500

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
460 feet to 500 feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 500 feet

Date started 10-3-94, 19.....
 Date completed 10-6-94, 19.....

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>22</u>			

9. WATER LEVEL
 Static water level 448 feet below land surface
 Artesian flow 22 G.P.M. 22 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Driling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 928
 Signed [Signature]
 Date October 10, 1994