WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46728
Permit No.
Basin 089

NOTICE OF INTENT NO. 24223

1. OWNER Dennis & Debbie Stafford
MAILING ADDRESS 60 Darilyn Ln. Carson City NV 89704
ADDRESS AT WELL LOCATION 60 Darilyn Ln. Carson City NV 89704

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. 5[redacted] Issued by Water Resources
50-060-24 Parcel No.
New Washoe City Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	2	2
Brown Sands		2	8	6
Gray Silty Sands		8	63	55
Gray Gummy Clay / Solid Clay zone		63	91	28
Fine DG Sands Green and White Some Coarse		91	140	49

'94 NOV -2 P 4:58
STATE ENGINEER

Date started 10-26, 19 94
Date completed 10-28, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	40	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10¼ Inches	0 Feet	145 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	145

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 145 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. 25+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company Contractor
Address 5551 Hwy 60 E #3 Contractor
Carson City NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 10-

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627