XX

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

23aaaa

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46729
Permit No.
Basin 103

NOTICE OF INTENT NO. 26819

1. OWNER Gary Hembree Const.
MAILING ADDRESS 306 Ruby Ln. Carson City NV 89701
ADDRESS AT WELL LOCATION 6025 Pursig Carson City NV 89701

2. LOCATION NE ¼ NE ¼ Sec. 23 T. 15 N S R. 20 E. Carson City County
PERMIT NO. 10-087-16 (Issued by Water Resources)
Parcel No. 010-087-16
Pinion Hills (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
DG Sands		3	36	33
Large Volcanic Gravels		36	125	89
Tight Volcanic Clay		125	145	20
Small Volcanic Sands		145	183	38
Large Gravels	XXX	183	235	52

NOV -2 P 4:53 '94
STATE ENGINEER'S OFFICE

Date started 10-27, 19 94
Date completed 10-31, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	25	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 1/4	0	50
9 7/8	50	235

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	235

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From 195 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 235 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Hot °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 (Contractor)
Carson City NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 11-1-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627