WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46731
Permit No.
Basin ~~009~~ 012

NOTICE OF INTENT NO. 2934

1. OWNER Michael B. Stewart
MAILING ADDRESS P.O. Box 40
Empire Nev. 89405
ADDRESS AT WELL LOCATION P.O. Box 255
Cedarville, Calif. 96104
10 mi. S. of Vya - Mosquito Ranch

2. LOCATION NW ¼ NE ¼ Sec. 6 T. 45N N/S R. 20 E. Washoe County

PERMIT NO. NON DESIGNATED BASIN (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☑ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brn. Sand		0	5	5
Red Sand		5	30	25
Red Sand + Gravel		30	95	65
Bright Red gravel, Red Clay		95	105	10
White Clay - Small gravel		105	110	5
D.C. - Volcanic Rock		110	125	15
Frac. Fresh Granite		125	140	15
Coarse Sand - Small gravel		140	185	45
Fine Sand - Small Gravel		185	220	35
Decomposed Granite		220	230	10
Fine Gray Sand		230	270	40
Gravel	✓	270	280	10
Fine Gray White Hard Sand		280	300	20
Gravel	✓	300	305	5
Decomposed Granite		305	340	35

'94 NOV -2 A11:49 STATE ENGINEER'S OFFICE

Date started 10-9-94, 19
Date completed 10-14-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	35	150	4 hrs

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	340 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 1/2	15#		0	340

Perforations:
Type perforation Slot
Size perforation 1/8 to 1/4
From 250 feet to 348 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 340 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name San Emidio Resources (Contractor)
Address P.O. Box 40 (Contractor)
Empire, Nev. 89405
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1558
Signed Michael W. Clark (By driller performing actual drilling on site or contractor)
Date 11-1-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627