WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 46736
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER Sam King
MAILING ADDRESS 5719 Gerkin Rd. Bishop, Calif. 93514
ADDRESS AT WELL LOCATION 621 Pete Henrichs Rd. Yerington, Nev. 89447

2. LOCATION SE ¼ SW ¼ Sec. 35 T. 14 N/S R. 26 E Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 04-141-12
LOT 1 Hungry Horse Sub Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy		0	3	3
Coarse Sand - Gravel		3	22	19
Rock - Sand - Gravel		22	32	10
Coarse Sand - Gravel		32	45	13
Coarse Sand - Gravel Few Rock		45	70	25
Coarse Sand - Gravel Clay STrates		70	130	60
Brown Clay - Small Gravel		130	150	20
Brown Clay - Coarse Sand - Small Gravel		150	175	25
Brown Clay - Sand		175	198	23
Coarse Sand	X	198	209	11
Coarse Sand - Clay		209	228	19
Coarse Sand - Small Gravel	X	228	231	3
Brown Clay - Coarse Sand		231	240	9
Coarse Sand - Clay STratas	X	240	260	20
Coarse Sand - Few Rock	XXX	260	279	19

Date started 9-15, 1994
Date completed 9-19, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	20	9.5	1/2 HR.
AIR LIFT	60	200' air Line	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 279 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	57 Feet
9 7/8	Inches	57 Feet	279 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	279

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 234 feet to 279 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 279 feet

9. WATER LEVEL
Static water level 120' 6" feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor)
Yerington, Nev. 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-3-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627