WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46738
Permit No.
Basin 108

NOTICE OF INTENT NO.

1. OWNER John Angle
MAILING ADDRESS P.O. Box 67 Smith Nev 89430
ADDRESS AT WELL LOCATION 31 N. Bybee Lane Yerington Nev 89447

2. LOCATION SE ¼ NE ¼ Sec. 34 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. Issued by Water Resources
14-381-35 Parcel No.
Parcel C PM176210 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy		0	3	3
Coarse Sand				
Gravel - few Rock		3	38	35
Coarse Sand - Gravel				
Clay		38	44	6
Coarse Sand - Gravel		44	66	22
Coarse Sand - Gravel -				
Clay		66	85	19
Coarse Sand - Gravel		85	90	5
Clay - Coarse Sand -				
Gravel		90	110	20
Coarse Sand - Gravel		110	143	33
Clay - Gravel		143	157	14
Coarse Sand - Gravel	X	157	164	7
Clay - Gravel		164	172	8
Coarse Sand - Gravel	X	172	178	6
Clay		178	186	8
Coarse Sand - Gravel	X	186	199	13

Date started 11-21, 19 94
Date completed 11-29, 19 94

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	20	2	½ HR

8. WELL CONSTRUCTION
Depth Drilled 199 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	199

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	199

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 159 feet to 199 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 199 feet

9. WATER LEVEL
Static water level 93 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. Bybee Lane Contractor
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 6-34
Signed [signature] By driller performing actual drilling on site or contractor
Date 11-30-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627