

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

46753
OFFICE USE ONLY
Log No. _____
Permit No. 59823-T
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 13196

1. OWNER Las Vegas Valley Water Dist
MAILING ADDRESS 1001 S. Valley View
Las Vegas, Nevada 89153
ADDRESS AT WELL LOCATION NE Corner
West side of Grand Canyon Dr., North
of Cheyenne Ave.
2. LOCATION NE 1/4 SE 1/4 Sec 7 T. 20 N9 R. 60 E Clark County
PERMIT NO. 59823T
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Not logged		0	100	
Gravelly sand		100	170	
Fine gravel & sand		170	185	
Gravelly sand		185	240	
Coarse to fine sand, trace				
fine gravel		240	290	
Gravelly sand		290	320	
Fine gravel & sand		320	540	
Well graded sand, trace of gravel		540	560	
Gravelly sand		560	610	
Fine gravel & sand		610	650	
Fine to med. sand, trace fine gravel		650	780	
Fine to coarse sand, trace fine gravel		780	980	
Fine to coarse sand, trace fine gravel with trace of red sand		980	1070	
Fine to med. sand, trace fine gravel, increase red sand content		1070	1090	
Fine to med. red sand, trace of coarse sand		1090	1156	

8. WELL CONSTRUCTION
Depth Drilled 1156 Feet Depth Cased 1120 Feet
HOLE DIAMETER (BIT SIZE)
From 34 Inches To 0 Feet 1140 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
24 97 3/8" +2 1120
Perforations: Stainless Steel Type 304
Type perforation .100"
Size perforation .100"
From 680 feet to 780 feet
From 820 feet to 1080 feet
Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 100 ft.
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 0 feet to 1140 feet

Date started Oct. 17, 1994
Date completed Jan. 14, 1995

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
Static Water Level	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
583.2	1110	57.2	24

9. WATER LEVEL
Static water level 583.2 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____
10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BEYLIK DRILLING, INC. Contractor
Address 555 S. Harbor Blvd. Contractor
La Habra, Calif. 90631
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
Signed T. Calhoun for Beylik Drilling
By driller performing actual drilling on site or contractor
Date Jan. 16, 1995 (Revised 2/2/95) Well #96

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13196

1. OWNER Las Vegas Valley Water Dist. ADDRESS AT WELL LOCATION
MAILING ADDRESS 1001 S. Valley View
Las Vegas, Nevada 89153
2. LOCATION NE 1/4 SE 1/4 Sec. 7 T. 20 N/S R. 60 E Clark County
PERMIT NO. 59823T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Not logged		0	100	
Gravelly sand		100	170	
Fine gravel & sand		170	185	
Gravelly sand		185	240	
Coarse to fine sand, trace fine gravel		240	290	
Gravelly sand		290	320	
Fine gravel & sand		320	540	
Well graded sand, trace of gravel		540	560	
Gravelly sand		560	610	
Fine gravel & sand		610	650	
Fine to med. sand, trace fine gravel		650	780	
Fine to coarse sand, trace fine gravel		780	980	
Fine to coarse sand, trace fine gravel with trace of red sand		980	1070	
Fine to med. sand, trace fine gravel, increase red sand content		1070	1090	
Fine to med. red. sand, trace coarse sand		1090	1156	

8. WELL CONSTRUCTION
Depth Drilled 1156 Feet Depth Cased 1120 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 1140 Feet
34 Inches 0 Feet 1140 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
24 97 3/8" +2 1120
Perforations:
Type perforation Copper Wire Wrap
Size perforation .100"
From 680 feet to 780 feet
From 820 feet to 1080 feet
Surface Seal: Yes No Seal Type:
Depth of Seal 100 ft. Neat Cement
Placement Method: Pumped Poured Cement Grout Concrete Grout
Gravel Packed: Yes No
From 0 feet to 1140 feet

9. WATER LEVEL
Static water level 583.2 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BEYLIK DRILLING, INC. Contractor
Address 555 S. Harbor Blvd. Contractor
La Habra, Calif. 90631
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
Signed Ted Caldwell for Beylik Drilling
By driller performing actual drilling on site or contractor
Date Jan. 16, 1995

Date started Oct. 17th, 1994
Date completed Jan. 14, 1995

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
Pump Level	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
638.6	1139	554	24