WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46756
Permit No.
Basin 212

NOTICE OF INTENT NO. 13254

1. OWNER: RANDY McCARTHY
MAILING ADDRESS:
ADDRESS AT WELL LOCATION: DEERSPRINGS & EGAN CREST

2. LOCATION: NW ¼ SE ¼ Sec. 24 T. 19 N/S R. 59 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND + ROCKS | | 0 | 5 | 5 |
| CMT GRAVEL | | 5 | 100 | 95 |
| CLAY + GRAVEL. | | 100 | 110 | 10 |
| CMT GRAVEL | | 110 | 390 | 280 |
| LIMESTONE | | 390 | 405 | 15 |
| CMT GRAVEL | | 405 | 420 | 15 |
| CLAY | | 420 | 430 | 10 |
| CMT GRAVEL | 590 | 430 | 700 | 270 |

RECEIVED
JAN 30 1995
Division of Water Resources
Branch Office - Las Vegas, NV

Date started: 12-23, 1994
Date completed: 1-3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 1/4 Inches | 0 Feet | 700 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | +1 | 700 |

Perforations:
Type perforation: FACTORY SAW.
Size perforation: 1/8 X 2 1/2
From 660 feet to 680 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 700 feet

9. WATER LEVEL
Static water level 540' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): DESERT DRILLING
Address (Contractor): 6475 GARY AVE
LAS VEGAS, NV.
Nevada contractor's license number issued by the State Contractor's Board: 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1966
Signed: (By driller performing actual drilling on site or contractor)
Date: 1-17-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627