WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46761
Permit No.
Basin

NOTICE OF INTENT NO. 10908

1. OWNER Ralph W Davies
MAILING ADDRESS Box 265 Pahrump NEV 89041
ADDRESS AT WELL LOCATION Block B LOT 7 MESQUITE AVE

2. LOCATION NW ¼ NW ¼ Sec. 6 T. 20S N/S R. 53 E. NyE County
PERMIT NO. (Issued by Water Resources) 36-024-07 (Parcel No.) LAND MARK Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brn Clay		1	5	4
Grey Clay		5	28	23
Brn Clay	WB	28	44	16
Brn Clay Hard		44	71	27
Brn Clay	WB	71	106	35
Hard Grey Clay		106	117	11
Brn Clay	WB	117	125	8
Hard Brn Clay		125	140	15

RECEIVED
NOV 18 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Nov 2, 19 94
Date completed Nov 10, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	3'	2h

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12½ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17.11	188	0	140

Perforations:
Type perforation Torch Cut
Size perforation ¼ X 6"
From 92 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ron Naillon Drilling (Contractor)
Address Box 265 Pahrump NEV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1625
Signed Ron Naillon (By driller performing actual drilling on site or contractor)
Date Nov - 12 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627