

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14242

1. OWNER Rayna Meloughlin Lori Ann August ADDRESS AT WELL LOCATION Teton & Palomita
 MAILING ADDRESS Sandy Valley, Clark

2. LOCATION N12 1/4 NW 1/4 Sec. 22 T. 24S N/S R. 56 E County _____
 PERMIT NO. 580-160-060 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Cobbles		0	25	25
Cemented Gravel		25	28	3
Clay		28	39	11
Cemented Gravel		39	49	10
Clay		49	57	8
Caliche		57	61	4
Clay		61	68	7
Caliche		68	72	4
Clay		72	77	5
Caliche		77	81	4
Clay		81	92	11
Caliche		92	94	2
Clay		94	100	6
Caliche		100	106	6
Clay		106	117	11
Caliche		117	122	5
Clay		122	126	4
Caliche		126	128	2
Clay		128	143	15
Caliche		143	149	6
Clay		149	175	26

DIV. of Water Resources
 Branch Office - Las Vegas, NV
 NOV 22 1994
 RECEIVED

8. WELL CONSTRUCTION
 Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 175
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 7/8	16.97	1.88	±1	175

Perforations:
 Type perforation SAW
 Size perforation 7/8 inch by 3 inch
 From 155 feet to 175 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50 FT.

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 175 feet

Date started _____, 1994
 Date completed _____, 1994

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 90 FT. feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor
 Address HIR 78 Box 80358 Contractor
Pahrump NV. 89041

Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 11-16-94