



Log No. 46776  
 Permit No. \_\_\_\_\_  
 Basin 230

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 192-29

1. OWNER Sam Carey ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 2070  
Amargosa Valley, NV. 89020  
 2. LOCATION NW 1/4 SW 1/4 Sec. 35 T. 165 N/S R 49 E NYE County  
 PERMIT NO. 19-631-37 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	20	20
Cement Gravel		20	65	45
Cement Gravel & Clay		65	90	25
Clay		90	110	20
Cement Gravel	WB	110	130	20
Cement Gravel & Clay		130	165	35

RECEIVED  
 NOV 22 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION  
 Depth Drilled 165 Feet Depth Cased 165 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches 0 Feet 165 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>1694</u>	<u>.188</u>	<u>0</u>	<u>165</u>

Perforations:  
 Type perforation Factory Saw Cut  
 Size perforation 1/8 x 3  
 From 1.48 feet to 165 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 165 feet

9. WATER LEVEL  
 Static water level 96 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started November 3, 1994  
 Date completed November 4, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling  
 Address HR 78 Box 80358  
Pahrump, NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Sam  
 By driller performing actual drilling on site or contractor  
 Date 11/16/94