

OFFICE USE ONLY  
 Log No. 46781  
 Permit No. 212  
 Basin 212



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13053

1. OWNER June Habbeshaw (Valentine) ADDRESS AT WELL LOCATION N/A  
 MAILING ADDRESS N/A

2. LOCATION SW 1/4 NE 1/4 Sec. 27 T 19S N/S R. 60 E Clark County  
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Popcorn Caliche		0	15	
Hard Caliche		15	20	
Clay		20	90	
Hard Caliche		90	100	
Clay		100	195	
Clay & Water	XX	195	215	
Clay		215	320	
Clay & Water	XX	320	350	

8. WELL CONSTRUCTION  
 Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 350 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	350

Perforations:  
 Type perforation Factory  
 Size perforation 3/16 x 8 row  
 From 306 feet to 330 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5.5 \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 5.5 feet to 350 feet

9. WATER LEVEL  
 Static water level 162 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

RECEIVED

NOV 18 1994

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 10/29/94, 19\_\_\_\_\_  
 Date completed 11/10/94, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor  
 Address 5360 Bonita Vista Contractor  
Las Vegas Nev. 89129

Nevada contractor's license number issued by the State Contractor's Board 10062  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed V H Dimick  
 By driller performing actual drilling on site or contractor  
 Date 11-11-94