(4)

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46783
Permit No. 54628
Basin 212

NOTICE OF INTENT NO. 13441

1. OWNER Fred Abraham Rao Jerrinsette
MAILING ADDRESS
ADDRESS AT WELL LOCATION El Capitan

2. LOCATION NE ¼ NW ¼ Sec. 29 T. 19 N/S R. 60 E. Clark County
PERMIT NO. 54628 (Issued by Water Resources) 500-380-025 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
Om
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders W/ silty clay		0	130	130
Brn Clay		130	180	50
Brn Clay w/ Gravel & boulders		180	243	63
Cemented Gravels		243	290	47
Fractured Limestone		290	385	95

RECEIVED
JAN 1 2 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

11-3

NE NW

Date started 10-20, 1994
Date completed 10-25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	Pump 2 hours	

8. WELL CONSTRUCTION
Depth Drilled 385 Feet Depth Cased 385 Feet

HOLE DIAMETER (BIT SIZE)
12¼ Inches From +10 Feet To 385 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188		

Perforations:
Type perforation Torch
Size perforation 1/4" x 8"
From 325 feet to 385 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☑ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 38 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60 °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mitchell Enterprises (Contractor)
Address 2255 E. Sunset Rd #1056 (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 27030
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Dean Mitchell (By driller performing actual drilling on site or contractor)
Date 11-3-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627