WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 46784
Log No.
Permit No.
Basin
NOTICE OF INTENT NO. 12454

1. OWNER PECOS TERRACE APARTMENTS C/O
MAILING ADDRESS HALLMARK HOMES
531 CALIFORNIA AVENUE, BAKERSFIELD, CA 93304

ADDRESS AT WELL LOCATION
PECOS TERRACE APTS.
PECOS & LAKE MEADE

2. LOCATION NW ¼ SW ¼ Sec. 19 T 20 N/S R 62 E E CLARK County

PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
8" CASING HAD 1½" X 1¼" JET PUMP SET 63 FT. DEEP, BUT WAS FILLED WITH ROCKS & BOARDS.				
WE DUG DOWN TO 22 FT. WITH BACKHOE AND TORCH CUT CASING. WE THEN REMOVED THE DEBRIS AND CLEANED WELL.				
STATIC WATER LEVEL 33 FT.				
WELL DEPTH 89 FT. 8 5/8" WELL CASING.				
USED 3 YARDS 21 SACK CEMENT SLURRY.				
1½ YARDS IN WELL.				
1½ YARDS FOR CAP AT 12 FT. LEVEL.				
BACKFILL WITH DIRT TO THE GROUND LEVEL.				

RECEIVED
NOV 16 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-21-94, 19
Date completed 4-21-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916/0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B. Allen Jr. (By driller performing actual drilling on site or contractor)
Date NOVEMBER 10, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627