

OFFICE USE ONLY  
 Log No. 94801  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 14234

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Desert Oasis Homes ADDRESS AT WELL LOCATION Lot 17 Mariposa  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SE 1/4 Sec. 34 T 205 N/S R 53 E Nye County  
 PERMIT NO. 40-693-06 Parcel No. Calvada Valley Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Caliche		0	10	10
Clay		10	25	15
Caliche		25	28	3
Clay		28	55	27
Caliche	WB	55	60	5
Clay		60	72	12
Caliche	WB	72	75	3
Clay		75	90	15
Caliche	WB	90	93	3
Clay		93	116	23
Caliche	WB	116	120	4
Clay		120	140	20

RECEIVED  
 NOV 29 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 140  
12.25 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.9</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Saw Cut  
 Size perforation 1/8" x 3"  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started November 7, 1994  
 Date completed November 8, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358  
Pahrump, NV 89041 Contractor

Nevada contractor's license number 30880  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas P. ...  
 By driller performing actual drilling on site or contractor

Date 11/21/94