WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46807
Permit No.
Basin: 162

NOTICE OF INTENT NO. 14189

1. OWNER: Tom Terry
MAILING ADDRESS:
ADDRESS AT WELL LOCATION: 3951 W. Dyer

2. LOCATION: NW ¼ NW ¼ Sec. 13 T 20-S N/S R 52 E Nye County
PERMIT NO. (Issued by Water Resources): 28-703-01 (Parcel No.)
Subdivision Name: Charleston Park Ranchos Unit 2

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Gray clay		4	16	12
Gray clay/caliche		16	52	36
Brown clay	X	52	104	52
Brown clay/caliche		104	126	22
Green clay	X	126	140	14

RECEIVED
DEC 02 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started: Nov. 18, 1994
Date completed: Nov. 18, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled: 140 Feet Depth Cased: 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation: Factory Cut
Size perforation: 1/8"width 3"long (8 rolls)
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal: 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level: 43 feet below land surface
Artesian flow: G.P.M. P.S.I.
Water temperature: °F Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): JIM PIKE WELL DRILLING, LLC
Address (Contractor): P.O. Box 56
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board: 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1812
Signed: William A. Pike
By driller performing actual drilling on site or contractor
Date: Nov. 23, 1994

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627