WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46816
Permit No.
Basin 162

NOTICE OF INTENT NO. 14330

1. OWNER Austin Altom
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5051 Jerry St.

2. LOCATION SW ¼ SE ¼ Sec 16 T 19S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 29-283-08 (Parcel No.) Country Place II (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Dirt		0	3	3
Clay		3	9	6
Calichie		9	14	5
Clay		14	18	4
Calichie		18	29	11
Clay		29	36	6
Calichie		36	42	6
Clay		42	51	9
Gravel-Sand-Clay		51	63	12
Clay		63	74	11
Gravel-Sand-Clay		74	82	8
Clay		82	95	13
Sand-Gravel	WB	95	104	5
Clay		104	122	18
Calichie	WB	122	125	3
Clay		125	140	15
Calichie	WB	140	145	5
Clay		145	156	11
Calichie	WB	156	167	11
Clay		167	172	9
Calichie	WB	172	175	3

Date started January 13, 19 95
Date completed January 16, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
FEB 14 1995
Div. of Water Resources
Bureau Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 175 Feet Depth Cased 175 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	175 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	175

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 97 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dem
By driller performing actual drilling on site or contractor
Date 1/31/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627