WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46819
Permit No.
Basin
NOTICE OF INTENT NO. 14327

1. OWNER KLH Construction
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2400 Yucca Terrace

2. LOCATION SW ¼ NW ¼ Sec. 29 T. 20S N/S R. 53 E. Nye County
PERMIT NO. Issued by Water Resources | 39-012-23 Parcel No. | Calvada Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	6	6
Calichie		6	8	2
Clay		8	18	10
calichie		18	23	5
Clay		23	31	8
Calichie		31	33	2
Clay		33	46	13
Calichie		46	48	2
Clay		48	52	4
Calichie	WB	52	56	4
Clay		56	67	11
Calichie	WB	67	69	2
Clay		69	81	12
Calichie	WB	81	84	3
Clay		84	100	18
Calichie	WB	100	105	5
Clay		105	113	8
Calichie	WB	113	115	2
Clay		115	124	9
Calichie	WB	124	127	3
Clay		127	138	11
Calichie	WB	138	140	2

Date started January 2, 1995
Date completed January 4, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
FEB 14 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 1 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 1/31/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627