WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46820
Permit No.
Basin 162

NOTICE OF INTENT NO. 12296

1. OWNER Jim Porter
MAILING ADDRESS
ADDRESS AT WELL LOCATION Blosser Ranch Rd.

2. LOCATION NE ¼ SE ¼ Sec. 34 T. 19S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 27-401-20 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~Cemented Gravel~~		~~0~~	~~8~~	~~8~~
~~Clay~~		~~8~~	~~15~~	~~7~~
~~Calichie~~		~~15~~	~~17~~	~~2~~
~~Clay~~		~~17~~	~~25~~	~~8~~
~~Calichie~~		~~25~~	~~27~~	~~2~~
~~(Cemented Conglom~~		~~27~~	~~46~~	~~15~~
~~rate rock)~~				
~~Calichie~~		~~46~~		
~~Clay~~		~~46~~		
Cemented Gravel		0	8	8
Clay		8	15	7
Calichie		15	17	2
Clay		17	25	8
Calichie		25	27	2
Clay		27	46	19
Cemented Conglom-rate rock		46	60	14
Clay		60	79	19
Calichie		79	82	3
Clay		82	109	27
Clay + Gravel		109	128	19
Clay		128	135	7
Calichie	WB	135	146	11
Clay		146	153	7
Calichie	WB	153	170	17
Clay		170	180	10

Date started January 9, 19 95
Date completed January 11, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
FEB 14 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	180

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 2-3-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627