

OFFICE USE ONLY
 Log No. 4683
 Permit No. 149
 Basin 149

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2209

1. OWNER Loran & Edith Rudolph ADDRESS AT WELL LOCATION MVR unit 5 BLK 62-2-4
Elko NV Spring Valley PKW Kitridge Canyon
 MAILING ADDRESS 950 Spring Valley PKW
 2. LOCATION SE 1/4 SW 1/4 Sec 35 T. 35 N/S R 55 E Elko County
 PERMIT NO. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top soil</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>River Boulders</u>		<u>2</u>	<u>18</u>	<u>16</u>
<u>Clay sand</u>		<u>18</u>	<u>24</u>	<u>8</u>
<u>Granite</u>		<u>24</u>	<u>290</u>	<u>264</u>
<u>Fracture Granite</u>	<u>X</u>	<u>240</u>	<u>342</u>	<u>52</u>
<u>Granite</u>		<u>342</u>	<u>355</u>	<u>13</u>

8. WELL CONSTRUCTION
 Depth Drilled 355 Feet Depth Cased 355 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 355 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>355</u>

 Perforations:
 Type perforation Factory
 Size perforation _____
 From 295 feet to 335 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal soft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 355 feet

94 DEC -7 AM 1:14
 STATE ENGINEERS OF

Date started NOV - 19 1994
 Date completed NOV - 23 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>0</u>	<u>2</u>

9. WATER LEVEL
 Static water level 251 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Contractor
 Address 181-14 West Bullion Contractor
Elko NV
 Nevada contractor's license number issued by the State Contractor's Board 0020684
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Shaw Bennett
 By driller performing actual drilling on site or contractor
 Date NOV - 23 - 94