WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 46824
Permit No.
Basin 103

NOTICE OF INTENT NO. 24231

1. OWNER Rick & Karen Hoare
MAILING ADDRESS 12395 Shawnee Rd. Silver Springs NV 89429
ADDRESS AT WELL LOCATION 12395 Shawnee Rd Silver Springs NV 89429

2. LOCATION SE ¼ SE ¼ Sec. 12 T 17 N/S R 22 E Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 15-323-18 | Subdivision Name Iron Mtn. Ranch

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Large Cobbles & Boulders		3	27	24
Black & White Granite Loose Gravels		27	45	18
DG Sands		45	83	38
Hard DG Granite		83	205	122
Broken DG Sands small Clay Seams		205	245	40
Broken DG Gravels	XXX	245	265	20
Loose DG Gravels	XXX	265	300	35

Date started 12-8, 1994
Date completed 12-15, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	110	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10¼	Inches	0	Feet	60	Feet
9 7/8	Inches	60	Feet	300	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	300

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. 10 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hock (By driller performing actual drilling on site or contractor)
Date 12-13-94

DEC 15 '94 P 2:08 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627