WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46827
Permit No. 55140
Basin 061

NOTICE OF INTENT NO. 25585

1. OWNER Barrick Goldstrike Mine
MAILING ADDRESS P.O. Box 29
Elko, NV 89801

ADDRESS AT WELL LOCATION
Barrick Goldstrike Mine

2. LOCATION NE ¼ SW ¼ Sec. 19 T 36 N/S R 50 E Eureka County
PERMIT NO. 55140 (Issued by Water Resources) | n/a (Parcel No.) | n/a (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Lt. Brwn. Rock & Clay		0	130	130
Brwn. Gray Rock & Clay		130	170	40
Hard Brwn. Black Rock		170	230	60
Black Gray Rock & clay		230	310	80
Gray Clay Some Rock		310	430	120
Brwn. Clay with Limestone		430	490	60
Gray Black Clay		490	630	140
Brwn. Clay and Gray Rock		630	830	200
Gray Clay		830	870	40
Brwn. Clay		870	910	40
Gray Clay		910	990	80
Green Rock & white clay		990	1030	40
Black RK. Some Clay		1030	1110	80
Black Clay Some rock		1110	1320	210

Date started September 20, 1994
Date completed October 7, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1320 Feet Depth Cased 1311 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
25	Inches	0	Feet	20	Feet
19	Inches	20	Feet	1320	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	53	.250	0	20
12	34	.250	0	151
12	34	.250	191	351
12	34	.250	551	631
12	34	.250	1111	1191

Perforations:
Type perforation Louvered
Size perforation 1/8"

From 151 feet to 191 feet
From 351 feet to 551 feet
From 631 feet to 1111 feet
From 1191 feet to 1311 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 1320 feet

9. WATER LEVEL
Static water level 430 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature 108 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address 2286 West 1500 South (Contractor)
Salt Lake City, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1796

Signed Ron Behrendt (By driller performing actual drilling on site or contractor)

Date October 11, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627