WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 46830
Permit No.
Basin 161

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12364

1. OWNER All & Lisa Smail
MAILING ADDRESS Cold Creek So. NV.
None Mailing Address
ADDRESS AT WELL LOCATION Cold Creek So. NV

2. LOCATION SE ¼ SE ¼ Sec. 36 T. 17 N/S R. 55 E. Clark County
PERMIT NO. (Issued by Water Resources) OLD# 540-540-029 (Parcel No.) New# 092-36-801-006 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Unconsolated Rock		0	100	100
Rainbow Sand Stone		100	120	20
Consolated Lime Stone		120	200	80
Factured in Places				
Small Water	158			
Strata	174			
	185			
	193			

RECEIVED
DEC 09 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-27, 1994
Date completed ~~10-23~~ 12-5, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6	180	45 min
Draw Down To 170'		
in 45 min		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 3/4 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5		188	0	200

Perforations:
Type perforation Factory
Size perforation 7/16" x 3"
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☒ Poured Both
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. 6 P.S.I.
Water temperature 42 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bryce Robinson (Contractor)
Address Po Box 807 (Contractor)
PUNU 89041
Nevada contractor's license number issued by the State Contractor's Board 15972
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 944
Signed ~~10/28/94~~ Bryce Robinson (By driller performing actual drilling on site or contractor)
Date ~~10-28-94~~ 12-5-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627