WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46843
Permit No. 55620
Basin

NOTICE OF INTENT NO. 14127

1. OWNER Richard Baugman
MAILING ADDRESS 6221 Arlington Ave
Las Vegas Nev. 89107

ADDRESS AT WELL LOCATION 300 YDS behind Store at Sunnyside Nev.

2. LOCATION S/W ¼ S/W ¼ Sec. 36 T. 7 N/S R. 61 E. NYE County
PERMIT NO. 55620 (Issued by Water Resources) 12 (Parcel No.) Bert Hooks Subdivision (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	6	6
white clay-sand		6	70	64
gravel-brown clay	X	70	94	24
white clay		94	103	9
TD 103'				

RECEIVED
DEC 12 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-30, 19 94
Date completed 12-1-, 19 94

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
28	40	2

8. WELL CONSTRUCTION
Depth Drilled 103 Feet Depth Cased 103 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	103 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	-0-	.188	0	103

Perforations:
Type perforation Factory
Size perforation 1/8" x 3"
From 63 feet to 103 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 103 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow -0- G.P.M. -0- P.S.I.
Water temperature Cold °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling (Contractor)
Address P.O. Box 54 Hiko Nev. 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike D Davis (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627