


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 4684
 Permit No. _____
 Basin 170


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 14125

1. OWNER D C Day ADDRESS AT WELL LOCATION Highway # 375
 MAILING ADDRESS Star Route Box 33 Rachel Nev. 89017
Alamo Nev. 89001
 2. LOCATION N/W 1/4 S/W 1/4 Sec. 36 T. 3 N. 55 E. Lincoln County
 PERMIT NO. 10-173-03 Sunset Acres Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	18	18
Sand - boulders		18	70	52
Coarse sand	X	70	167	97
Hard Rock		167	170	3
TD 170'				

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 170 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>0</u>	<u>.188</u>	<u>0</u>	<u>170</u>

Perforations:
 Type perforation factory
 Size perforation 1/8" x 3/4"
 From 110 feet to 130 feet
 From 150 feet to 170 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 170 feet

9. WATER LEVEL
 Static water level 76 feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature cold °F Quality good

RECEIVED
 DEC 12 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 11-21-94, 19____
 Date completed 11-22-94, 19____

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>28</u>	<u>4</u>	<u>2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling Contractor
 Address PO. Box 54 Hiko Nev. 89017 Contractor
 Nevada contractor's license number issued by the State Contractor's Board. 0028966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1121
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 11-23-94

