

OFFICE USE ONLY
 Log No. _____
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27507

1. OWNER MOLINE CONSTRUCTION ADDRESS AT WELL LOCATION 1906 CATHERINE CT
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec 1 T 12 N R 20 E DOUGLAS County
 PERMIT NO. 23-480-72 WILDFLOWER Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/ GRAVEL		0	43	43
SAND + GRAVEL		43	49	6
SANDY CLAY		49	111	62
SANDY CLAY w/ GRAVEL		111	140	29
SAND + GRAVEL		140	157	17
SANDY CLAY w/ GRAVEL		157	171	14
SANDY CLAY		171	205	34
CLAY		205	287	82
CEMENTED GRAVEL		287	292	5
CLAY		292	318	26
SANDY CLAY w/ GRAVEL		318	328	10
SAND + GRAVEL	✓	328	335	7
SANDY CLAY w/ GRAVEL		335	346	11
SAND + GRAVEL	✓	346	357	11
CLAY		357	358	1
CEMENTED GRAVEL		358	360	2

94 DEC 12 P4:18
 STATE ENGINEERS OFF.

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 50 Feet
9 7/8 Inches 50 Feet 360 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>360</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 340 feet to 360 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 360 feet

9. WATER LEVEL
 Static water level 175 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDOW EXPLORATION, INC
 Contractor
 Address 7780 CURRY RD
 Contractor FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1726
 Division of Water Resources, the on-site driller
 Signed Pat J. May
 By driller performing actual drilling on site of contractor
 Date 11-17-94

Date started 11-1, 1994
 Date completed 11-17, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25 +</u>	<u>—</u>	<u>4</u>