

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26563

1. OWNER STAN FAIL ADDRESS AT WELL LOCATION 1516 EAST VALLEY RD. GARDNERVILLE, NV
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 35 T. 13 N. R. 20 E DOUGLAS County
 PERMIT NO. 23-295-62 Parcel No. _____ Subdivision Name EAST VALLEY
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	31	31
SANDY CLAY		31	62	31
CLAY		62	65	3
SANDY CLAY		65	88	23
SANDY CLAY w/GRAVEL		88	92	4
SANDY CLAY		92	113	21
CLAY		113	131	18
SANDY CLAY		131	158	27
SANDY CLAY w/GRAVEL		158	163	5
SAND + GRAVEL	✓	163	166	3
SANDY CLAY w/GRAVEL		166	196	30
SAND + GRAVEL	✓	196	219	23
SANDY CLAY		219	220	1

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 220 feet

9. WATER LEVEL
 Static water level 59 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 11-18, 1994
 Date completed 11-25, 1994

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Paul J. Mooy
 By driller performing actual drilling on site or contractor
 Date 11-25-94