X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46868
Permit No.
Basin 102

NOTICE OF INTENT NO. 26001

1. OWNER Bill Johnson
MAILING ADDRESS 1001 E. 7th St. Silver Springs, NV. 89429

ADDRESS AT WELL LOCATION 7th & Elm St S.S. Nv, 89429

2. LOCATION NW ¼ SW ¼ Sec. 18 T. 17 N/S R. 25 E. Lyon County

PERMIT NO. ____ Issued by Water Resources | 15-611-03 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Sand,		0	22	22
Sand Gravel		22	56	34
Cemented Gravel		56	63	7
Sand	GPM	63	86	23
Cemented Gravel	(6)	86	115	29
(Clay, Streak Some Sand Stone)	X	115	146	
Fractured Sand Stone, Cemented Gravels	X	146	160	

'94 NOV 15 A11:28
RECEIVED
STATE ENGINEERS OFF.

Date started 9/27/94, 19
Date completed 9/30/94, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	gpm (+)		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 161' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	1 Feet	160' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15.50	1.88	+1	160'

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 8 x 5 rows per
From 140' feet to 160' feet
From 135' feet to 140' feet
From 115 feet to 120' feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 160' feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature W °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc (Contractor)
Address PO 599 S.S. (Contractor)
Nv 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature] By driller performing actual drilling on site or contractor

Date 11/8/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627