

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25824

1. OWNER BILL A CRANE 19 W HANNOM ADDRESS AT WELL LOCATION West End of  
 MAILING ADDRESS Blvd SAGINAW MI Elko Summit Dr Lot 9B  
99602

2. LOCATION SW 1/4 SW 1/4 Sec 25 T 34 N15 R 55 E PIRO County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. Lot 9B Subdivision Name Elko Summit Estates  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam		0	4	4
White SANDSTONE		4	80	76
White CLAY		80	85	5
White SANDSTONE		85	145	60
White CLAY		145	150	5
Loose SANDSTONE	X	150	152	2'
White SANDSTONE		152	205	53
Loose SANDSTONE	X	205	210	5

94 NOV 14 P 10:55

8. WELL CONSTRUCTION

Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>210</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12.92</u>	<u>1.88</u>	<u>12</u>	<u>210</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/16 x 3"  
 From 183 feet to 210 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 51 feet to 210 feet

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fentig Drilling Co Contractor  
 Address P.O. Box 525 Contractor  
Elko NV 89801  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Harold Fentig  
 By driller performing actual drilling on site or contractor  
 Date 11-9-94

Date started 11-4, 19\_\_\_\_\_  
 Date completed 11-9, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40+</u>		<u>4.1</u>