

OFFICE USE ONLY
 Log No. 4087
 Permit No. 048
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25820

1. OWNER BILL A CAANE ADDRESS AT WELL LOCATION LOT 7A
 MAILING ADDRESS 19 W Hannum Blvd ELKO Vista Drive and 4th
SAGINAW MI 48620 W 4th Way
 2. LOCATION NW 1/4 NW 1/4 Sec 25 T 34 N 1/2 S 5 E ELKO County
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name Elko Summit Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sod soil		0	3	3
White SANDSTONE		3	180	177
ROSE SANDSTONE	X	180	185	5
CLAY		185	200	15
White SANDSTONE		200	289	89
ROSE SANDSTONE	X	289	292	3
White SANDSTONE		292	300	8

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		6.5

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	12.92	1.88	12	300

 Perforations:
 Type perforation slots
 Size perforation 3/4 x 3"
 From 160 feet to 180 feet
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 54 feet to 300 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 61.6 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fentig Drilling Co Contractor
 Address P.O. Box 525 Contractor
ELKO NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shovel C. Fentig
 By driller performing actual drilling on site or contractor
 Date 10-13-94