

OFFICE USE ONLY  
 Log No. 410874  
 Permit No. \_\_\_\_\_  
 Basin 045

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25828

1. OWNER SONNIE Milano 173-2 ADDRESS AT WELL LOCATION 148 Lot 2  
 MAILING ADDRESS Pleasant Valley Crow BAR Lane Pleasant Valley

2. LOCATION SW 1/4 NW 1/4 Sec. 26 T 33 N/S R. 57 E Elk County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. 23-005-02-6 Subdivision Name Pleasant Valley

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand soil</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Clay</u>		<u>2</u>	<u>4</u>	<u>2</u>
<u>Deepening Gravel</u>		<u>4</u>	<u>55</u>	<u>49</u>
<u>Gravel</u>		<u>55</u>	<u>128</u>	<u>100</u>
<u>Thin gravel</u>	<u>A</u>	<u>150</u>	<u>170</u>	<u>12</u>

94 NOV 14 P 1 35  
 STATION

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 170 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.42</u>	<u>188</u>	<u>+2</u>	<u>170</u>

Perforations:  
 Type perforation slots  
 Size perforation 3/4" x 3'  
 From 158 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 53  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 53 feet to 170 feet

9. WATER LEVEL  
 Static water level 84 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address PO Box 525 Contractor  
2110 N. 57501  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554  
 Signed Shoule Fertig  
 By driller performing actual drilling on site or contractor  
 Date 10-30-94

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>2.5</u>		<u>4:05</u>