WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46879
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 26003

1. OWNER Sindy Greer
MAILING ADDRESS 1930 Clearview Court. Fallon NV. 894
ADDRESS AT WELL LOCATION 1930 Clearview Court

2. LOCATION NW ¼ NE ¼ Sec 24 T 19 N/S R 28 E Churchill County
PERMIT NO. Issued by Water Resources | 08-261-28 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan Clay		0	3	3
Sand		3	10	7
Sand And Gravel		10	25	10
Gravel		25	85	60
Gray Clay with Some Sand		85	101	16
Tan Clay		101	113	12
Sand with Gravel	✓	113	120	7

Date started 11-12, 19 94
Date completed 11-14, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for 2 Hours And produced about 50 Gallons A min.		

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	5/16	+1	120

Perforations:
Type perforation Torch Cut
Size perforation 1/4 X 6 Long X 5 Rows
From 113 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed Nathan Leach (By driller performing actual drilling on site or contractor)
Date 11/15/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627