

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27493

1. OWNER William Cameron ADDRESS AT WELL LOCATION 1925 So. Rel. Lane Gardnerville NV.
MAILING ADDRESS P.O. Box 2441 Gardnerville NV 89410

2. LOCATION NE 1/4 NW 1/4 Sec. 24 T. 12 N/S R. 20 E Douglas County
PERMIT NO. 27-452-200* FROM NOV Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen
 Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Previous 8" well		0	147	147'
Boulders		147	154	7'
Sand		154	156	2'
Gravel & Boulders		156	166	10'
Sandy clay - soft		166	168	2'
Gravel & Boulders		168	185	17'
Broken Basalt	X	185	190	5'
Fractured Basalt		190	256	66'

94 NOV -2 AM 1:50
STATE ENGINEERS OF I
New APN 1220-24-10010010

8. WELL CONSTRUCTION
Depth Drilled 256 Feet Depth Cased 256 Feet

HOLE DIAMETER (BIT SIZE)
From 7 7/8 Inches 147 Feet To 256 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 7/8</u>		<u>.188</u>	<u>0</u>	<u>256</u>

Perforations:
Type perforation mill slot
Size perforation 5/8 x 3
From 176 feet to 190 feet
From 216 feet to 236 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 50 ft Cement Grout
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
From 50 feet to 256 feet

9. WATER LEVEL
Static water level 128 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 58 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Inland Pacific Drilling Co Inc Contractor
Address Po Box 831 Yerington NV 89447 Contractor

Date started September 8, 1994
Date completed September Oct 5, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>50</u>		<u>3</u>
<u>PUMP</u>	<u>23</u>	<u>4</u>	<u>2</u>

Nevada contractor's license number issued by the State Contractor's Board 0036582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 12217-1
Signed Joel W Brown
By driller performing actual drilling on site or contractor
Date Oct 12 1994