WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46904
Permit No.
Basin 162

NOTICE OF INTENT NO. 13653

1. OWNER Hector Nagliett
MAILING ADDRESS
ADDRESS AT WELL LOCATION North Blood Ranch Rd Pahrump Valley

2. LOCATION SW ¼ NE ¼ Sec. 21 T. 18S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 270-07105 (Parcel No.) NA. (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Gravel Cobbles		0	55	55
Cemented Sand & Gravel		55	120	65
Sandy Clay & Pea Gravel		120	165	45
Black Volcanic Rock		165	200	35
Cemented Sand & Gravel		200	285	85
Sand & Small Gravel		285	300	15
Cemented Sand & Gravel		300	380	80
Cemented Sand & Gravel		380	445	65
Sandy Clay Gravel		445	535	90
Sand & Gravel		535	575	40
Cemented Sand & Gravel		575	685	110
Sandy Clay & Gravel		685	715	30
Cemented Sand & Gravel		715	790	75
Sand & Gravel	WB	790	950	160

RECEIVED DEC 21 1994 Div. of Water Resources Branch Office - Las Vegas, NV

Date started 8-18, 1994
Date completed 9-25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 950 Feet Depth Cased 950. Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17½ Inches		0 Feet	50 Feet
12¼ Inches		50 Feet	950 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12¾	25.22	.188.	0	55
8⅝	16.97	.188.	0	950

Perforations:
Type perforation SAW.
Size perforation ⅛ inch by 3 inch.
From 770 feet to 790 feet
From 810 feet to 830 feet
From 850 feet to 870 feet
From 890 feet to 910 feet
From 930 feet to 950. feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 950 feet

9. WATER LEVEL
Static water level 760 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCB 78 Box 80358 Pahrump NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 38880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
Signed (By driller performing actual drilling on site or contractor)
Date 10-14-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627