WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46907
Permit No.
Basin 163

NOTICE OF INTENT NO. 6160

1. OWNER John CLEMENT
MAILING ADDRESS HCR 31 Box 718 Sandy Valley, NV 89019
ADDRESS AT WELL LOCATION 2807 SHOSHONE Sandy Valley NV 89019

2. LOCATION NE ¼ NW ¼ Sec 22 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. (Issued by Water Resources) 580-160-135-95 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	12	12
ALUVIUM		12	54	42
CORAL		54	88	34
ALUVIUM		88	98	10
CONS CLAY BRN		98	105	7
CALICHE	WTR	105	109	4
CONS CLAY BRN		109	121	12
SANDY CLAY WHT		121	125	4
CALICHE	WTR	125	130	5
ROCK & CLAY BRN		130	156	26
WHITE CLAY		156	168	12
BRN CLAY		168	172	4
CALICHE	WTR	172	180	8

RECEIVED
DEC 19 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Oct 20, 19 94
Date completed Nov 15, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	38	2

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	180 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	18	.188	0	180

Perforations:
Type perforation FLAME CUT
Size perforation 5/16 X 3"
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 80 feet to 180 feet

9. WATER LEVEL
Static water level 101 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 68 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB INC. (Contractor)
Address 1701 W CHSTN BLVD LAS VEGAS NV 89102 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Spurlock (By driller performing actual drilling on site or contractor)
Date Dec. 5-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627