WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46933
Permit No.
Basin 162

NOTICE OF INTENT NO. 14319

1. OWNER Michael McKim
MAILING ADDRESS
ADDRESS AT WELL LOCATION 4730 Savoy

2. LOCATION SE ¼ NE ¼ Sec. 20 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 45-292-24 Subdivision Name Green Saddle Ranch

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	7	7
Calichie		7	17	10
Clay		17	27	10
Calichie		27	29	2
Clay		29	38	9
Calichie		38	43	5
Clay		43	55	12
Calichie	WB	55	59	4
Clay		59	67	8
Calichie	WB	67	72	5
Clay		72	81	9
Calichie	WB	81	84	3
Clay		84	90	6
Calichie	WB	90	94	4
Clay		94	99	5
Calichie	WB	99	106	7
Clay		106	118	12
Calichie	WB	118	121	3
Clay		121	131	10
Calichie	WB	131	136	5
Clay		136	140	4

RECEIVED
JAN 04 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started December 22, 1994
Date completed December 27, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.184	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 12/27/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627