WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46942
Permit No.
Basin 162

NOTICE OF INTENT NO. 14313

1. OWNER Joanne Speakman
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 8 Bond St

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-431-68 (Parcel No.) Cal Vista Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	6	6
Calichie		6	8	2
Clay		8	14	6
Calichie		14	16	2
Clay		16	23	7
Calichie		23	26	3
Clay		26	41	15
Calichie		41	44	3
Clay		44	55	10
Calichie		55	58	3
Clay		58	66	8
Calichie		66	69	3
Clay		69	82	13
Calichie	WB	82	84	2
Clay		84	103	19
Calichie	WB	103	105	2
Clay		105	109	4
Calichie	WB	109	112	3
Clay		112	121	9
Calichie	WB	121	125	4
Clay		125	138	13
Calichie	WB	138	144	6
Clay		144	147	3
Calichie	WB	147	150	3

Date started December 16, 1994
Date completed December 19, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED JAN 30 1995 DIV. of Water Resources Eastern Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	150

Perforations:
Type perforation Factory Saw Cut
Size perforation 8" x 3"
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1462 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 12/30/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627