

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

in Book

Log No. 46952
 Permit No. 56665
 Basin _____

NOTICE OF INTENT NO. 12738

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Richard B. & Joanne Harrison ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2000 San Jose _____
Las Vegas, NV _____

2. LOCATION NW 1/4 NE 1/4 Sec 24 T. 22 N/S R. 60 E Clark County
 PERMIT NO. 56665 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	80	80
Gravel & clay		80	100	20
Sand & gravel		100	150	50
Clay & gravel		150	170	20
Gravel		170	270	100
Sand & gravel		270	302	32
Cemented gravel		302	402	100
Gravel		402	500	98

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 491 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches ~~30~~ Feet 500 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22.36	1/4"	+1	491

Perforations:
 Type perforation Mill slots
 Size perforation 1/8 x 2 1/2" 8 rows
 From 391 feet to 471 feet
 From _____ feet to _____ feet

RECEIVED
 FEB 13 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 500 feet

9. WATER LEVEL
 Static water level 302 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started December 10, 1994
 Date completed February 9, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name S.B. McKinney & Sons Contractor
 Address 8036 McCarroll St Contractor
Las Vegas, NV

Nevada contractor's license number issued by the State Contractor's Board 2065
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 290-T

Signed S.B. McKinney & Sons
 By driller performing actual drilling on site or contractor

Date February 13, 1995