

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

210 N. CARSON  
 NOTICE OF INTENT NO. 208 N. CARSON ST  
CARSON CITY NV

1. OWNER F. I. B ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 208 N. CARSON ST  
CARSON CITY NV  
 2. LOCATION S.W. 1/4 NW 1/4 Sec. 17 T. 15 N/S R. 30 E County \_\_\_\_\_  
 PERMIT NO. MD 866 3-213-02 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>		<u>0</u>	<u>1'</u>	
<u>SANDY silt</u>		<u>1'</u>	<u>15</u>	
<u>silt</u>		<u>15'</u>	<u>20</u>	
<u>silty gravelly SAND</u>		<u>20'</u>	<u>25'</u>	
<u>sandy silt</u>		<u>25</u>	<u>30</u>	
<u>silty gravelly SAND</u>		<u>30</u>	<u>31.5</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 31.5 Feet Depth Cased 29.5 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12" Inches To 1' Feet  
 From 8" Inches To 31.5 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40</u>	<u>0</u>	<u>31.5</u>

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation 020  
 From 14.5 feet to 29.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 8  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8 feet to 12 feet

9. WATER LEVEL  
 Static water level 18.18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 2-13, 1998  
 Date completed 2-13, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
		<u>52 gal removed</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Nevada Drilling Inc Contractor  
 Address 75 Jewers Creek RD Contractor  
CARSON CITY NV  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902  
 Signed John B. Dewar  
 By driller performing actual drilling on site or contractor  
 Date 3-3-95