WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46975
Permit No.
Basin 103

NOTICE OF INTENT NO. 24229

1. OWNER Julius Bunkowski
MAILING ADDRESS Mound House NV.

ADDRESS AT WELL LOCATION Permit # W417
Exploratory Test Hole
Dayton NV. 89429

2. LOCATION SW ¼ NW ¼ Sec. 24 T. 16 N/S R. 21 E. Lyon County
PERMIT NO. W-417 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other Exploratory

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large Cobbles and Gravels		0	25	25
1/4" Gravels w/small Inbeded Gravels		25	165	140
Small Brown Clay		165	173	8
Inbeded Gravels		173	225	52
Layer of Brown Clay		225	240	15
Inbeded Sands and Gravels		240	275	35
Small Sands and Clay		275	310	35
Brown tight Clay with Small Boulders		310	400	90

Date started 11-21, 1994
Date completed 11-25, 1994

'95 JAN -6 P1:01
STATE ENGINEERS OFF

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	40	4 HRS

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	400 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
N/A				

Perforations:
Type perforation
Size perforation
From N/A feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. 60 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 (Contractor)
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-1-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627