

46992  
 OFFICE USE ONLY  
 46991  
 Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin 087

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20718

Consultant:

1. OWNER Steffen Robertson & Kirsten ADDRESS AT WELL LOCATION Winners Corner  
 MAILING ADDRESS 1755 E. Plumb Ln, Suite 241 1600 B St./ 1600 Vitoria Ave.  
Reno, NV Sparks, NV

2. LOCATION SE  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 5 T. 19N N/S R 20 E. Washoe County  
 PERMIT NO. M/O#655-C MW#8 032-122-18 Sparks  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Tubex \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	3"	3"
Aggregate Base		3"	2.5	2.1
Brown silty sand with trace gravel, non-plastic, loose slightly moist		2.5	12.5	10
Dark Brown Silty Gravel with some cobbles, non-plastic, loose, moist		12.5	18	5.5
Boulder (Granite)		18	18.25	.25
Light Brown Silty Gravel, non-plastic, loose, saturated.		18.25	38.5	20.25
Light Brown Silty Gravel (GM), non-plastic, loose, saturated,		20.25	34.0	

8. WELL CONSTRUCTION  
 Depth Drilled 34 Feet Depth Cased 18.5 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
9 5/6 Inches 0 Feet 34 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	18.5
1" PVC Sparge line		SCH 40	0	34
2" PVC Sparge line		SCH 40		

Perforations:  
 Type perforation Factory Sawn Slot  
 Size perforation 0.020  
 From 8.5 feet to 18.5 feet 4"  
 From 32 feet to 34 feet 2"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-6  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Bentonite Seal: 6 to 7 feet & 25-29'  
 Gravel Packed:  Yes  No #8 Silica Sand  
 From 7-25 feet to 29-34 feet

9. WATER LEVEL  
 Static water level 17.8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. N/A P.S.I.  
 Water temperature N/A °F Quality N/A

Date started 5/12/94, 19\_\_\_\_\_  
 Date completed 5/12/94, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 908

Signed [Signature] By driller performing actual drilling on site or contractor  
 Date February 28, 1995