WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46992 46991
Permit No.
Basin 087

NOTICE OF INTENT NO. 20718

Consultant:

1. ~~OWNER~~ Steffen Robertson & Kirsten
MAILING ADDRESS 1755 E. Plumb Ln., Suite 241
Reno, NV

ADDRESS AT WELL LOCATION Winners Corner
1600 B St./ 1600 Vitoria Ave.
Sparks, NV

2. LOCATION SE ¼ SW ¼ Sec. 5 T. 19N N/S R. 20 E. Washoe County
PERMIT NO. M/O#655-C MW#8 (Issued by Water Resources) 032-122-18 (Parcel No.) Sparks (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	3"	3"
Aggregate Base		3"	2.5	2.1
Brown silty sand with trace gravel, non-plastic, loose slightly moist		2.5	12.5	10
Dark Brown Silty Gravel with some cobbles, non-plastic, loose, moist		12.5	18	5.5
Boulder (Granite)		18	18.25	.25
Light Brown Silty Gravel, non-plastic, loose, saturated.		18.25	38.5	20.25
Light Brown Silty Gravel(GM), non-plastic, loose, saturated,		20.25	34.0	

'95 MAR -6 P2:44
STATE ENGINEERS OFFICE

Date started 5/12/94, 19
Date completed 5/12/94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test			

8. WELL CONSTRUCTION
Depth Drilled 34 Feet Depth Cased 18.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/6 Inches		0 Feet	34 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	18.5
1" PVC	Sparge line	SCH 40	0	34
2" PVC	Sparge line	SCH 40		

Perforations:
Type perforation Factory Sawed Slot
Size perforation 0.020
From 8.5 feet to 18.5 feet 4"
From 32 feet to 34 feet 2"
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-6
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 6 to 7 feet & 25-29'
Gravel Packed: ☒ Yes ☐ No #8 Silica Sand
From 7-25 feet to 29-34 feet

9. WATER LEVEL
Static water level 17.8 feet below land surface
Artesian flow G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date February 28, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627